

Ventilation:

The Ventilation unit to be used: compliant with Wavin Ventiza Xtra Small. Ventilation unit should be a wall mounted unit and equipped with integrated humidity sensor including intelligent controls for adjustable RH parameters.

Heat recovery efficiency must be min 90 % at basic airflow & SFP performance not to exceed 1.000 J/m³.

An extra set of G4/F7 filters should be included for replacement after 3 months running time.

To prevent disbalance of air rates the unit must have integrated bypass with modulating damper.

Controlling of the unit should be by App, to prevent further electrical installations and need for display.

Regarding after sales service & support

The Ventilation unit must have option to have exhaust air spigot situated in front left of the unit for the purpose of inspection of fire damper.

The unit should be prepared for support by remote access.